

Local Authority Building Standards Scotland [LABSS]



Sent by E-mail to Please ask Mike.Harwood@Greags.co.uk Please ask for: - 01835 823479

Mike.Harwood@Greggs.co.ukfor: -01835 823479jwhiteford@scotborders.gov.uk07980 286987Alan.McAulay@southlanarkshire.gov.ukE-mail: roberta

E-mail: robertarenton@bobr.org.uk

Your ref: Mike Harwood

Copied to Ref: STAS/17/081/ND24/01

Greggs Plc, Greggs House, Quorum

Business Park, Newcastle upon Tyne, NE12 8BU

Date: 1 October 2018

Dear Sirs

Building (Scotland) Act 2003

SCOTTISH TYPE APPROVAL SCHEME [STAS]: Greggs Plc – Commercial Fit Out

I acknowledge receipt of your application for a Non-Domestic Type Approval for a **Commercial Fit Out** including

Shopfront Details:

 7 typical shop front variations including stall riser, threshold details, automatic door specifications and roller shutter details.

Partitions and fixings:

14 partition details, perimeter walling detail and selector cabinet bulkhead detail.

Door Schedule:

• Schedule covers the vast majority of door types in a Greggs shop.

Standard Drainage:

Standard 2D drawing to replace custom isometric drawings.

Drainage Pumps:

- 5 pumps and applications. Alternative approach to Guidance Clause 3.7.2: 'Wastewater lifting plants should be constructed in accordance with BS EN 12056-4: 2000'
- Pump Technology Ltd Drainmaster 30 meets:
- Pump Technology Ltd Efflu Maxi 80 meets:
- Pump Technology Ltd Drainmajor GRCS 60 meets:
- Pump Technology Ltd Drainmajor GRDW 60 meets:
- Pump Technology Ltd Flushmaster meets:

Typical Staff Room:

• 3 variations.

Typical Staff Toilet:

 Typical layout. Non-accessible. (Note no-worse provision when assessing applications that are not new builds, shell fit outs or constitute conversions.)

Typical Office:

Typical layout plan.

Accessible Service Counter for Greggs Bakers PLC:



Local Authority Building Standards Scotland [LABSS]



• Fixed counter installation to allow use by wheelchair users. Alternative approach to Guidance Clause 4.2.10 previously approved under STAS/13/051/RD05/01.

Typical Extract and Ventilation:

Standard extract and ventilation arrangements.

Example Building Warrant Drawing Submissions:

- Example 1 Small Premises
- Example 2 Medium Premises
- Example 3 Large Premises
- Example 4 Extra Large Premises

received on 29 June 2017 and would advise that this is now approved on 1 October 2018.

NON-DOMESTIC Scottish Borders Council	Greggs Plc, Greggs House, Quorum Business Park, Newcastle upon Tyne, NE12 8BU	Commercial Fit Out (see above)	STAS/17/O81/ND24/01	
---	---	--------------------------------	---------------------	--

Yours faithfully

Robert A Renton
Secretary to STAS

CC

Alan McAulay, STAS Chairman, Building Standards Team Leader (HQ) Planning and Building Standards Services, Montrose House, 154 Montrose Crescent, HAMILTON, ML3 6LB