

### Local Authority Building Standards Scotland [LABSS]



formerly the Scottish Association of Building Standards Managers [SABSM]

# House Type Approval Certificate

 Certificate No:
 STAS/18/015/DM54/03/AMD04

 Date:
 01 February 2019

A Certificate Holder:

Springfield Properties, Springfield House, 3 Central Park Avenue, Larbert, FK5 4RX

E-mail: craig.veldon@springfield.co.uk Tel: 01324 555536

B House Type Titles:

Description: Melford – 5B 1603CT detached two storey house with integrated garage

The domestic type approval has been assessed on the following drawings and specifications:

See attached annexe to this certificate

Wind: (as defined in BS 6399-2)	Standard effective wind speed, Ve = For maximum effective height = Has funnelling been considered?	44.1 m/s 10.0m NO
<b>Wind:</b> (as defined in CP3: Chapter V)	Design wind speed, Vs = (relevant to the building frame, at a height of 3m or less)	25.5 m/s
Snow: (as defined in BS 6399-3)	Site snow load, So = Influenced by adjacent buildings?	0.75 Kn/m2 NO
Resistance to moisture/durability of exposed elements:	Max exposure (to wind driven rain) grading, as defined in BRE Report – Thermal Insulation: Avoiding Risks, Second Edition, 1994, to be exposure zone:  Exposure to sea spray (i.e. coastal region) or de-icing salts?  Other air contaminants or biological factors – please specify any enhanced resistance if applicable (refer to BS7543 for guidance)	Zone 4
	ermanced resistance in applicable (refer to B07040 for guidance)	

#### E Conditions of certification:

- The design shown and the specifications and materials referred to have been assessed and approved in accordance with the Building (Scotland) Regulations 2004 and in accordance with the supporting guidance in the Domestic Technical Handbooks which came into force with effect from 1 July 2017.
- 2. The certificate shall be valid until invalidated by formal notice by the Local Authority Building Standards Scotland
- The design shown and the materials specified shall not be changed without reference to the Local Authority Building Standards Scotland
  responsible for certifying the system.
- 4. Where reference is made on a plan or specification document to any Code of Practice, British or European Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate.
- 5. This certificate should not be regarded as a formal approval under the building warrant process prescribed by the Building (Scotland) Act 2003 enacted from 1 May 2005
- The Bill Henderson Consulting Engineer Ltd amended statement dated 26 October 2018 referenced here under Section G, confirm that a structural appraisal has been carried out. Further site-specific information MUST BE made available when a site-specific building warrant is sought. Such additional information should take cognisance of Procedural Guidance on Certification including information to be submitted with a Building Warrant Application dated April 2010 Version 2. Confirmation of a holistic approach to structural adequacy of the <a href="mailto:entire-completed building">entire-completed building</a> shall be provided by a registered engineer to the local authority within whose area the site specific dwelling is to be built.



## Local Authority Building Standards Scotland [LABSS]



formerly the Scottish Association of Building Standards Managers [SABSM]

Annexe of drawings, certificates and specification documents used in the assessment:

F	Drawing Number:	and specification documents used in the assessment:  Description:	
	1603dt(AS)001 A	Schedules Plot Works Layout, Gas & Air Source Heat Pump Hybrid Heating Services & Drainage Layout Foul Water Drainage Isometric	
	1603dt(AS)103 A		
	1603dt(AS)203		
	1603dt(AS)205 A		
	1603dt(AS)301 L	Ground Floor General Arrangement	
1603dt(AS)302 H First Floor General Arrangement			
	1603dt(AS)306 N	First Floor Services Layout	
	1603dt(AS)324 Q	Ground Floor Services Layout, Gas & Air Source Heat Pump Hybrid Heating	
	1603dt(AS)421 M Elevations – Standard Arrangement, Ground Floor Services Layout, Gas & Air Source Heat Pump		Rump Hybrid Hoating
1603dt(AS)501 Section A-A		ump riyond rieating	
	1603dt(AS)501	Section A-A Section B-B	
	1603dt(AS)503	Stair Sections	
	1603dt(AS)504 A	Stair Plans	
			)
1603dt(AS)601 C Floor Joist Layout			
		Roof Plan	
	DET(TK)03-01 B		
	DET(TK)03-02 A	Dwarf Wall Detail with Suspended Slab, Polished Finish	
		Garage Floor Detail	
		External Wall, Internal & External Corner Detail	
	DET(TK)04-02 B External Wall, Internal & External Corner Detail DET(TK)05-01 C Typical Cavity Barrier Positions		
	DET(TK)08-01 B	B Mid Floor Detail at External Wall, Parallel Joists	
	DET(TK)08-02 B		
	DET(TK)08-03 B	Mid Floor Detail at External Wall, Parallel Joists	
	DET(TK)11-07 B	40 degrees Eaves Detail at First Floor Wall Head	
	DET(TK)11-08 B	40 degrees Eaves Detail at First Floor Window Head	
	DET(TK)11-12 B	Verge Detail	
	DET(TK)11-13 A	GRP Valley Detail	
	DET(TK)14-01 B	Window Cill Detail – Ground Floor, Render	
	DET(TK)14-02 B	Window Cill Detail – First Floor, Render	
	DET(TK)14-05 A	Window Jamb Detail – Render	
	DET(TK)14-07 B	Window Head Detail – Ground Floor, Render	
	DET(TK)14-08 B	Window Head Detail – First Floor, Render	
	DET(TK)15-01 A	External Door Detail Level Access Threshold Polished Slab Finish	
	DET(TK)15-02 A	External Door Detail Stepped Access Threshold Polished Slab Finish	
	DET(TK)29-01	Timber Kit Hold Down strap Detail	
	DET(TK)29-02	Typical Roof Fixing Details Page 1	
	DET(TK)29-03	Typical Roof Fixing Details Page 2	
	DET(TK)29-04	Typical Roof Fixing Details Page 3	
	DET(TK)29-05	Typical Roof Fixing Details Page 4	
	DET(TK)29-06	Lintel Detail for Open Plan Option	
	CAS 8499_17	Vent Axia Melford 1603DT	
	608 S(MELF)25	Structural overlay	



## Local Authority Building Standards Scotland [LABSS]



formerly the Scottish Association of Building Standards Managers [SABSM]

G	Certification:	
	BRE Global Ltd Certificate of Design (Section6	For all house types
	– Energy)	
	STAS/13/053/RD06/01	Registered detail certificate for ventilation system
	Amended Statement of structural adequacy	From Bill Henderson Consulting Engineer Ltd dated 26 October 2018

H Specification:	
Springfield – 2019 Building Standards	For all house types
Technical Specification Mainstream Housing	-
Timber Frame	
Hybrid Air Source Heat Pump & Gas Central	
Heating, Date 01/01/2019	
Stroma SAP ratings 2012	For all house types
Section 6 Certificate of Design covering lette	Moda letter dated 17 December 2018
Sustainability Bronze Level	Melford
BRE report	Intermediate Floor sound test
Sound test c/03/5I/0835/1	Intermediate Floor sound test report
Vent Axia Lo-carbon dMEV unit	Manufacturers information for ventilation system
Bill Henderson Consulting Engineer Ltd	Introduction
Calculation Sheet 608(i)W1	
Bill Henderson Consulting Engineer Ltd	Notes for Timber Kit manufacture
Calculation Sheet 608(ii)W2	
U-value calculation	Floor – MELFORD 0.16
U-value calculation	Floor – exposed flor over garage 0.14
U-value calculation	Rendered External Wall 0.21
U-value calculation	Timber Clad External Wall 0.21
U-value calculation	Wall – garage wall – 145mm insulation 0.2
U-value calculation	Roof - main roof – 300mm insulation 0.15
U-value calculation	Roof – slope roof – 150 + 30mm insulation 0.14
U-value calculation	Wall – dwarf walls 150mm insulation 0.24
Robust Wall specification	Bill Henderson Consulting Engineer Ltd – letter and fixing specification dated 7 March 2017

- 1	Authority:		
	This system type approval certificate consisting of 3 pages is authorised by:	Signature:	Dallie,
	10	(	Lead Authority Building standards Manager on behalf of the Local Authority Building Standards Scotland (LABSS)

Appendix A

Regulation 9 Provisions on which dispensation is given	Decision	STAS Condition
Technical Standard 3.12 Sanitary facilities (Domestic) Every building must be designed and constructed in such a way that sanitary facilities are provided for all occupants of, and visitors to, the building in a form that allows convenience of use and that there is no threat to the health and safety of occupants or visitors.  Guidance Clause 3.12.3 of the Technical Handbook for dwellings identifies that walls adjacent to any sanitary facility are of robust construction that will permit secure fixing of grab rails or other aids in the zones noted in figure 3.32	Robust walls to structural engineers specification (Bill Henderson Consulting Engineer Ltd letter and fixing specification dated 7 March 2017)	Walls adjacent to any sanitary facility shall be constructed to Bill Henderson Consulting Engineer Ltd letter and fixing specification dated 7 March 2017)