

Local Authority Building Standards Scotland [LABSS]

Scottish Type Approval Scheme

formerly the Scottish Association of Building Standards Managers [SABSM]

House Type Approval Certificate

 Certificate No:
 STAS/17/043/DM72/13

 Date:
 11 December 2017

A Certificate Holder:

Bellway Homes Limited, Bothwell House, Hamilton Business Park, Caird Street, Hamilton, MI3 0QA

E-mail: Brian.McComish@bellway.co.uk Tel: 01698 477440

B House Type Titles:
Description: Maidstone (end) /Cypress (mid) - 4 block terrace (2015)

The domestic type approval has been assessed on the following drawings and specifications:

See attached annexe to this certificate

Wind: (as defined in BS 6399-2)	Standard effective wind speed, Ve =	24m/s
	For maximum effective height =	8m
	Has funnelling been considered?	NO
Wind: (as defined in CP3: Chapter V)	Design wind speed, Vs =	N/A
	(relevant to the building frame, at a height of 3m or less)	IN/A
<u> </u>	(relevant to the bunding frame, at a neight of on one cos)	
Snow: (as defined in BS 6399-3)	Site snow load, So =	0.75 Kn/m2
	Influenced by adjacent buildings?	NO
Resistance to moisture/durability of exposed elements:	Max exposure (to wind driven rain) grading, as defined in BRE Report –	Exposure Zone 4
	Thermal Insulation: Avoiding Risks, Second Edition, 1994, to be exposure	
	zone:	
	Exposure to sea spray (i.e. coastal region) or de-icing salts?	
	Other air contaminants or biological factors – please specify any	NO
	enhanced resistance if applicable (refer to BS7543 for guidance)	NO
Design Life: (per BS 7543 –	Category of building design life =	Unlimited
Design File: (Det BS 7543 =	L Calegory of building design life =	Uniimitea

E Conditions of certification:

- The design shown and the specifications and materials referred to have been assessed and approved in accordance with the Building (Scotland) Regulations 2004 and in accordance with the supporting guidance in the Domestic Technical Handbooks which came into force with effect from 1 July 2017.
- 2. The certificate shall be valid until invalidated by formal notice by the Local Authority Building Standards Scotland
- 3. The design shown and the materials specified shall not be changed without reference to the Local Authority Building Standards Scotland responsible for certifying the system.
- 4. Where reference is made on a plan or specification document to any Code of Practice, British or European Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate.
- 5. This certificate should not be regarded as a formal approval under the building warrant process prescribed by the Building (Scotland) Act 2003 enacted from 1 May 2005
- 6. The Dougall Baille Associates statement dated 31/10/2017 referenced here under Section G, confirm that a structural appraisal has been carried out. Further site-specific information MUST BE made available when a site-specific building warrant is sought. Such additional information should take cognisance of Procedural Guidance on Certification including information to be submitted with a Building Warrant Application dated April 2010 Version 2 (2017). Confirmation of a holistic approach to structural adequacy of the entire completed building shall be provided by a registered engineer to the local authority within whose area the site specific dwelling is to be built.
- 7. This certificate confirms compliance with mandatory standard 6.1. However, this is based on a notional 'worst case' criteria with regards to orientation, shading, sheltering and resultant PV array efficiency. Site specific information will be required to confirm the actual DER for the STAS approved house type on each plot on a particular site.



Local Authority Building Standards Scotland [LABSS]



on behalf of the Local Authority Building Standards Scotland (LABSS)

formerly the Scottish Association of Building Standards Managers [SABSM]

Annexe of drawings, certificates and specification documents used in the assessment: **Drawing Number:** Description: MAID-CYP TERR General arrangement (2015) T-KIT-001 rev C MAID-CYP TERR General arrangement (2015) T-KIT-002 rev B ENG_TF_220 rev A Foundation layout, ground floor plan & construction details (for reference only) ENG_TF_221 Vibro foundation layout and details (for reference only) ENG_TF_222 Steelwork details ENG_TF_223 rev D House type elevations Heating installation (Cypress) 17/221-001 17/221-002 Heating installation (Cypress) 17/221-003 Hot and cold water (Cypress) Hot and cold water (Cypress) 17/221-004 17/221-001 Heating installation (Maidstone) 17/221-002 Heating installation (Maidstone) 17/221-003 Hot and cold water (Maidstone) 17/221-004 Hot and cold water (Maidstone) TFb130/001 Timber frame layouts TFb130/002 Framing layouts GF TFb134/003 Framing layouts FF TFb130/004 FF framing TFb130/003 GF framing TF AA(1) Substructure details (refer to drawing register for revision details) TF AA(2) Superstructure details (refer to drawing register for revision details) Component details (refer to drawing register for revision details) TF AA(3) TF AA(5) Services details (refer to drawing register for revision details) External works details (refer to drawing register for revision details) TF AA(9) Door/Int/01 rev C Internal door schedule Drawing issue Latest version available on LABSS website register Certification: Statement of structural adequacy Dougall Baillie Associates 31/10/2017 Specification: Technical specification, timber frame Specification construction - rev A SAP ratings NHER compliance report U value calculations Authority: This system type approval certificate Signature: consisting of 2 pages is authorised by: Lead Authority Building standards Manager