



STAS/15/015/DM54/03 House Type Certificate No: Date: 22 November 2016 **Approval Certificate** Certificate Holder: Springfield Properties, Springfield House, 3 Central Park Avenue, Larbert, FK5 4RX E-mail: gregor.robertson@springfield.co.uk Tel: 01324 555536 R House Type Titles: Description: Melford – 5B 1603CT detached two storey house with integrated garage С The domestic type approval has been assessed on the following drawings and specifications See attached annexe to this certificate Climatic conditions: The design may be built in areas where the climatic conditions are equal to or less than those detailed below: D Wind: (as defined in BS 6399-2) Standard effective wind speed, Ve = 44.1 m/s For maximum effective height = 10.0m Has funnelling been considered? NO Wind: (as defined in CP3: Chapter Design wind speed, Vs = 25.5 m/s (relevant to the building frame, at a height of 3m or less) V) 0.75 Kn/m2 **Snow:** (as defined in BS 6399-3) Site snow load, So = Influenced by adjacent buildings? NO Max exposure (to wind driven rain) grading, as defined in BRE Report -Resistance to moisture/durability Zone 4 Thermal Insulation: Avoiding Risks, Second Edition, 1994, to be exposure of exposed elements: zone: Exposure to sea spray (i.e. coastal region) or de-icing salts? Other air contaminants or biological factors - please specify any enhanced resistance if applicable (refer to BS7543 for guidance) NO Category of building design life = Design Life: (per BS 7543 -60 years Durability of buildings and building elements, products and components) Design life of primary building envelope 60 years Conditions of certification: Ε The design shown and the specifications and materials referred to have been assessed and approved in accordance with the Building 1. (Scotland) Regulations 2004 and in accordance with the supporting guidance in the Domestic Technical Handbooks which came into force with effect from 1 October 2013. The certificate shall be valid until invalidated by formal notice by the Local Authority Building Standards Scotland 2. The design shown and the materials specified shall not be changed without reference to the Local Authority Building Standards Scotland 3. responsible for certifying the system. Where reference is made on a plan or specification document to any Code of Practice, British or European Standard or manufacturer's 4. instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate. This certificate should not be regarded as a formal approval under the building warrant process prescribed by the Building (S cotland) Act 5. 2003 enacted from 1 May 2005 The Bill Henderson Consulting Engineer Ltd statement dated 29 September 2015 referenced here under Section G, confirm that a structural 6. appraisal has been carried out. Further site-specific information MUST BE made available when a site-specific building warrant is sought. Such additional information should take cognisance of Procedural Guidance on Certification including information to be submitted with a Building Warrant Application dated April 2010 Version 2. Confirmation of a holistic approach to structural adequacy of the entire completed building shall be provided by a registered engineer to the local authority within whose area the site-specific dwelling is to be built.





Annexe of drawings, certificates and specification documents used in the assessment:

_		
F	Drawing Number:	Description:
_	1603dt(AS)001 A	Schedules
	1603dt(AS)101	Plot Works Layout
	1603dt(AS)203	Services & Drainage Layout
	1603dt(AS)205 A	Foul Water Drainage Isometric
	1603dt(AS)301	Ground Floor General Arrangement
	1603dt(AS)302	First Floor General Arrangement
	1603dt(AS)304 E	Ground Floor Services Layout
	1603dt(AS)306	First Floor Services Layout
	1603dt(AS)401	Elevations
	1603dt(AS)501	Section A-A
-	1603dt(AS)502 A	Section B-B
-	1603dt(AS)503	Stair Sections
-	1603dt(AS)504 A	Stair Plans
-	1603dt(AS)601 C	Floor Joist Layout
	1603dt(AS)602	Roof Plan
	1603dt(AS)701	Accessible Cloakroom Layout
	J7999-Melford-FF	Finnjoist (FJI) Kerto LVL
	Q17388AC	Roof Truss Layout
-	608 S1 W1	Structural Notes Timber Frame Construction
-	608 S2 W3	Timber Frame Typical Details Ground Bearing Floor Slab
-	608 S5 W1	Timber Frame Typical Details Suspended Slab
-	DET(TK)03-01 B	Ground Floor Detail with Suspended Slab, Polished Finish
-	DET(TK)03-02 A	Ground Floor Detail with Ground Bearing Slab, Polished Finish
-	DET(TK)03-07 B	Dwarf Wall Detail with Suspended Slab, Polished Finish
-	DET(TK)03-16	Garage Floor Detail
-	DET(TK)04-02 B	External Wall, Internal & External Corner Detail
-	DET(TK)05-01 C	Typical Cavity Barrier Positions
-	DET(TK)08-01 B	Mid Floor Detail at External Wall, Parallel Joists
	DET(TK)08-02 B	Mid Floor Detail at External Wall, Perpendicular Joists
	DET(TK)08-03 B	Mid Floor Detail at External Wall, Parallel Joists
	DET(TK)11-07 B	40 degrees Eaves Detail at First Floor Wall Head
-	DET(TK)11-08 B	40 degrees Eaves Detail at First Floor Window Head
	DET(TK)11-12 B	Verge Detail
-	DET(TK)11-13 A	GRP Valley Detail
	DET(TK)14-01 B	Window Cill Detail – Ground Floor, Render
	DET(TK)14-02 B	Window Cill Detail – First Floor, Render
	DET(TK)14-05 A	Window Jamb Detail – Render
	DET(TK)14-07 B	Window Head Detail – Ground Floor, Render
	DET(TK)14-08 B	Window Head Detail – First Floor, Render
-	DET(TK)15-01 A	External Door Detail Level Access Threshold Polished Slab Finish
-	DET(TK)15-02 A	External Door Detail Stepped Access Threshold Polished Slab Finish
-	DET(TK)29-01	Timber Kit Hold Down strap Detail
	DET(TK)29-02	Typical Roof Fixing Details Page 1
	DET(TK)29-03	Typical Roof Fixing Details Page 2
	DET(TK)29-04	Typical Roof Fixing Details Page 3
	DET(TK)29-05	Typical Roof Fixing Details Page 4
	CAS 8499_17	Vent Axia Melford 1603DT
	608 S(MELF)25	Structural overlay

G	Certification:	
	BRE Global Ltd Certificate of Design	For all house types
	(Section6 – Energy)	
	STAS/13/053/RD06/01	Registered detail certificate for ventilation system
	Statement of structural adequacy	From Bill Henderson Consulting Engineer Ltd dated 29 September 2015





H Specification:				
	Springfield – Technical Specification – Mainstream Housing, Bronze Standard Compliant Gas Central Heating Revision H	For all house types		
	Stroma SAP ratings	For all house types		
	BRE report	Intermediate Floor sound test		
	Sound test c/03/5I/0835/1	Intermediate Floor sound test report		
	Vent Axia Lo-carbon dMEV unit	Manufacturers information for ventilation system		
	Bill Henderson Consulting Engineer Ltd Calculation Sheet 608(i)W	Introduction		
	Bill Henderson Consulting Engineer Ltd Calculation Sheet 608(ii)W2	Notes for Timber Kit manufacture		
I	Authority:			
	This system type approval certificate consisting of 3 pages is authorised by:	Signature:		
		Lead Authority Building standards Manager		
		on behalf of the Local Authority Building Standards Scotland (LABSS)		
	pprovec			