

House Type Approval Certificate

Certificate No: **STAS/14/065/DM45/11**
Date: **13 July 2015**


A	Certificate Holder:	
	Keepmoat, The Waterfront, Lakeside Boulevard, Doncaster, DN4 5PL. E-mail: stu.king@keepmoat.com Tel: 01709 263156	
B	House Type Titles:	
	Description:	Cottage flat – 2B4P ‘four in a block’ style flatted dwellings
C	The domestic type approval has been assessed on the following drawings and specifications:	
	See attached annexe to this certificate	
D	Climatic conditions: The design may be built in areas where the climatic conditions are equal to or less than those detailed below:	
	Wind: (as defined in BS 6399-2)	Standard effective wind speed, V_e = For maximum effective height = Has funnelling been considered?
		24.4 m/s 8.5m NO
	Wind: (as defined in CP3: Chapter V)	Design wind speed, V_s = (relevant to the building frame, at a height of 3m or less)
		N/A
	Snow: (as defined in BS 6399-3)	Site snow load, S_o = Influenced by adjacent buildings?
	0.75 Kn/m2 NO	
Resistance to moisture/durability of exposed elements:	Max exposure (to wind driven rain) grading, as defined in BRE Report – Thermal Insulation: Avoiding Risks, Second Edition, 1994, to be exposure zone: Exposure to sea spray (i.e. coastal region) or de-icing salts? Other air contaminants or biological factors – please specify any enhanced resistance if applicable (refer to BS7543 for guidance)	Refer to SBA performance specification J3127-910: C3 Medium NO
Design Life: (per BS 7543 – Durability of buildings and building elements, products and components)	Category of building design life = Design life of primary building envelope	50 years 50 years
E	Conditions of certification:	
	1. The design shown and the specifications and materials referred to have been assessed and approved in accordance with the Building (Scotland) Regulations 2004 and in accordance with the supporting guidance in the Domestic Technical Handbooks which came into force with effect from 1 October 2013.	
	2. The certificate shall be valid until invalidated by formal notice by the Local Authority Building Standards Scotland	
	3. The design shown and the materials specified shall not be changed without reference to the Local Authority Building Standards Scotland responsible for certifying the system.	
	4. Where reference is made on a plan or specification document to any Code of Practice, British or European Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate.	
	5. This certificate should not be regarded as a formal approval under the building warrant process prescribed by the Building (Scotland) Act 2003 enacted from 1 May 2005	
	6. The Scott Bennett Associates (Group 2) Ltd statement dated 02/07/2015 referenced here under Section G, confirm that a structural appraisal has been carried out. Further site-specific information MUST BE made available when a site-specific building warrant is sought. Such additional information should take cognisance of Procedural Guidance on Certification including information to be submitted with a Building Warrant Application dated April 2010 Version 2. Confirmation of a holistic approach to structural adequacy of the <u>entire completed building</u> shall be provided by a registered engineer to the local authority within whose area the site specific dwelling is to be built.	

Annexe of drawings, certificates and specification documents used in the assessment:

F	Drawing Number:	Description:
	2014/653&725 - 100 rev D	GA working drawing sheet 1 of 2
	2014/653&725 - 101 rev B	GA working drawing sheet 2 of 2
	10271 - 11	Heating layout, schedule of equipment and installation notes (duplex flat 653)
	10271 - 12	Heating layout, schedule of equipment and installation notes (duplex flat 725)
	SD813	Timber frame junction with ground bearing slab
	SD814	Timber frame junction with suspended slab
	SD815	Timber frame junction with ground bearing slab – basic gas protection
	SD816	Timber frame junction with suspended slab – basic gas protection
	SD804 rev A	Threshold details
	SD817	Eaves and verge
	SD818	Roof – abutment and junction with gable
	SD819	Window – head, cill and jamb detail
	SD820 rev A	Intermediate floor details
	SD821	Wall type
	SD812	Boiler panel
	SD133	Junction of ceiling and roof at party wall
	J3127-211 rev A	Structural layout
	J3127-671	Engineering construction details
	J3127-910	Engineering performance specification
	J3127-911	Engineering construction notes
	653-725 TGI 01	STEICO joist layout

G	Certification:	
	V-FT-1 Robust Detail	Separating floor information
	V-WT-2 Robust Detail	Separating wall information
	STAS/13/053/RD06/01	Registered detail certificate for ventilation system
	Statement of structural adequacy	From Scott Bennett Associates (Group 2) Ltd dated 02/07/2015

H	Specification:	
	Keepmoat – Scottish technical standards general building specification (SAP 2009)	For cottage flat timber frame construction
	NHER SAP ratings	For cottage flats
	NHBC Services – U value calculations	For all elements
	Vent Axia Lo-carbon dMEV unit	Manufacturers information for ventilation system

I	Authority:		
	This system type approval certificate consisting of 2 pages is authorised by:	Signature:	
		Lead Authority Building standards Manager on behalf of the Local Authority Building Standards Scotland (LABSS)	