

## House Type Approval Certificate

Certificate No: **STAS/15/015/DM50/16**  
Date: **24 November 2015**

<b>A</b>	<b>Certificate Holder:</b>	Springfield Properties, Springfield House, 3 Central Park Avenue, Larbert, FK5 4RX	
	E-mail: <b>gregor.robertson@springfield.co.uk</b>	Tel: <b>01324 555536</b>	

<b>B</b>	<b>House Type Titles:</b>	Strathaven – 5B 2045dt detached two storey house with integrated garage	
	Description:		

<b>C</b>	The domestic type approval has been assessed on the following drawings and specifications:		
	<b>See attached annexe to this certificate</b>		

<b>D</b>	<b>Climatic conditions:</b> The design may be built in areas where the climatic conditions are equal to or less than those detailed below:		
	<b>Wind:</b> (as defined in BS 6399-2)	Standard effective wind speed, $V_e$ = For maximum effective height = Has funnelling been considered?	<b>44.1 m/s</b> <b>10.0m</b> <b>NO</b>
	<b>Wind:</b> (as defined in CP3: Chapter V)	Design wind speed, $V_s$ = (relevant to the building frame, at a height of 3m or less)	<b>25.5 m/s</b>
	<b>Snow:</b> (as defined in BS 6399-3)	Site snow load, $S_o$ = Influenced by adjacent buildings?	<b>0.75 Kn/m2</b> <b>NO</b>
	<b>Resistance to moisture/durability of exposed elements:</b>	Max exposure (to wind driven rain) grading, as defined in BRE Report – Thermal Insulation: Avoiding Risks, Second Edition, 1994, to be exposure zone: Exposure to sea spray (i.e. coastal region) or de-icing salts? Other air contaminants or biological factors – please specify any enhanced resistance if applicable (refer to BS7543 for guidance)	<b>Zone 4</b>  <b>NO</b>
	<b>Design Life:</b> (per BS 7543 – Durability of buildings and building elements, products and components)	Category of building design life =  Design life of primary building envelope	<b>60 years</b>  <b>60 years</b>


<b>E</b>	<b>Conditions of certification:</b>		
	1.	The design shown and the specifications and materials referred to have been assessed and approved in accordance with the Building (Scotland) Regulations 2004 and in accordance with the supporting guidance in the Domestic Technical Handbooks which came into force with effect from 1 October 2013.	
	2.	The inclusion of roof space smoke detection in lieu of roof space cavity barriers, while contrary to guidance, has been approved as an acceptable alternative approach – see Appendix A attached to and forming part of this certificate.	
	3.	The certificate shall be valid until invalidated by formal notice by the Local Authority Building Standards Scotland	
	4.	The design shown and the materials specified shall not be changed without reference to the Local Authority Building Standards Scotland responsible for certifying the system.	
	5.	Where reference is made on a plan or specification document to any Code of Practice, British or European Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate.	
	6.	This certificate should not be regarded as a formal approval under the building warrant process prescribed by the Building (Scotland) Act 2003 enacted from 1 May 2005	
	7.	The Bill Henderson Consulting Engineer Ltd statement dated May 2015 referenced here under Section G, confirm that a structural appraisal has been carried out. Further site-specific information MUST BE made available when a site-specific building warrant is sought. Such additional information should take cognisance of Procedural Guidance on Certification including information to be submitted with a Building Warrant Application dated April 2010 Version 2. Confirmation of a holistic approach to structural adequacy of the <u>entire completed building</u> shall be provided by a registered engineer to the local authority within whose area the site specific dwelling is to be built.	

**Annexe of drawings, certificates and specification documents used in the assessment:**

<b>F</b>	<b>Drawing Number:</b>	<b>Description:</b>
	2045DT(AS)000	Cover sheet drawing list
	2045DT(AS)001 C	Schedules
	2045dt(AS)101 C	Plot Works Layout
	2045dt(AS)205 A	Foul Water Drainage Isometric
	2045dt(AS)301 E	General Floor General Arrangement
	2045dt(AS)302 D	First Floor General Arrangement
	2045dt(AS)304 D	Ground Floor Services Layout
	2045dt(AS)305 D	First Floor Services Layout
	2045dt(AS)401 C	Elevations
	2045dt(AS)501 C	Section A-A
	2045dt(AS)502 A	Section B-B
	2045dt(AS)503 A	Stair Sections
	2045dt(AS)504 A	Stair Plans
	2045dt(AS)601 B	Floor Joist Layout
	2045dt(AS)602 A	Roof Plan
	2045dt(AS)701 D	Accessible Cloakroom Layout
	J1000 Strathavon	Finnjoist (FJI) Kerto LVL
	Q12593AT	Roof Truss Layout and Truss Profiles
	608 S1 W1	Structural Notes Timber Frame Construction
	608 S2 W3	Timber Frame Typical Details Ground Bearing Floor Slab
	608 S5 W1	Timber Frame Typical Details Suspended Slab
	DET(TK)03-01 B	Ground Floor Detail with Suspended Slab, Polished Finish
	DET(TK)03-02 A	Ground Floor Detail with Ground Bearing Slab, Polished Finish
	DET(TK)03-07 B	Dwarf Wall Detail with Suspended Slab, Polished Finish
	DET(TK)03-16	Garage Floor Detail
	DET(TK)04-01 B	Render on Lath Detail at Movement Joint to Masonry
	DET(TK)04-02 B	External Wall, Internal & External Corner Detail
	DET(TK)05-01 C	Typical Cavity Barrier Positions
	DET(TK)08-01 B	Mid Floor Detail at External Wall, Parallel Joists
	DET(TK)08-02 B	Mid Floor Detail at External Wall, Perpendicular Joists
	DET(TK)08-03 B	Mid Floor Detail at External Wall, Parallel Joists
	DET(TK)11-01 B	Render on Lath Detail at Roof Abutment
	DET(TK)11-02 B	Render on Lath Detail at Roof Eaves – Ground & First Floor Level
	DET(TK)11-07 B	40 degrees Eaves Detail at First Floor Wall Head
	DET(TK)11-08 B	40 degrees Eaves Detail at First Floor Window Head
	DET(TK)11-12 B	Verge Detail
	DET(TK)11-13 A	GRP Valley Detail
	DET(TK)14-01 B	Window Cill Detail – Ground Floor, Render
	DET(TK)14-02 B	Window Cill Detail – First Floor, Render
	DET(TK)14-03 B	Window Cill Detail - Ground Floor, Cladding
	DET(TK)14-04 B	Window Cill Detail – First Floor, Cladding
	DET(TK)14-05 A	Window Jamb Detail – Render
	DET(TK)14-06 C	Window Jamb Detail – Cladding
	DET(TK)14-07 B	Window Head Detail – Ground Floor, Render
	DET(TK)14-08 B	Window Head Detail – First Floor, Render
	DET(TK)14-09 C	Window Head Detail – Ground Floor, Cladding
	DET(TK)14-10 B	Window Head Detail – First Floor, Cladding
	DET(TK)15-01 A	External Door Detail Level Access Threshold Polished Slab Finish
	DET(TK)15-02 A	External Door Detail Stepped Access Threshold Polished Slab Finish
	DET(TK)29-01	Timber Kit Hold Down strap Detail
	DET(TK)29-02	Typical Roof Fixing Details Page 1
	DET(TK)29-03	Typical Roof Fixing Details Page 2
	DET(TK)29-04	Typical Roof Fixing Details Page 3
	DET(TK)29-05	Typical Roof Fixing Details Page 4
	CAS 8499_19	Vent Axia Stathavon 2045DT
	608 SK(STVN)20	Structural overlay
<b>G</b>	<b>Certification:</b>	

<b>BRE Global Ltd Certificate of Design (Section6 – Energy)</b>	For all house types
<b>STAS/13/053/RD06/01</b>	Registered detail certificate for ventilation system
<b>Statement of structural adequacy</b>	From Bill Henderson Consulting Engineer Ltd dated May 2015

<b>H</b>	<b>Specification:</b>	
	<b>Springfield – Technical Specification – Mainstream Housing, Bronze Standard Compliant Gas Central Heating Revision G</b>	For all house types
	<b>Elmhurst SAP ratings</b>	For all house types
	<b>BRE report</b>	Intermediate Floor sound test
	<b>Sound test c/03/51/0835/1</b>	Intermediate Floor sound test report
	<b>Vent Axia Lo-carbon dMEV unit</b>	Manufacturers information for ventilation system
	<b>Bill Henderson Consulting Engineer Ltd Calculation Sheet 608(ii)W2</b>	Notes for Timber Kit manufacture

<b>I</b>	<b>Authority:</b>	
	This system type approval certificate consisting of 3 pages is authorised by:	Signature: 
		Lead Authority Building standards Manager on behalf of the Local Authority Building Standards Scotland (LABSS)

**Appendix A**

Regulation 9 Provisions on which dispensation is given	Decision	STAS Condition
---	----------	----------------

**Technical Standard 2.4 Cavities (Domestic)**

Every building must be designed and constructed in such a way that in the event of an outbreak of fire within the building, the unseen spread of fire and smoke within concealed spaces in its structure and fabric is inhibited.

**Guidance Clause 2.4.2** of the technical handbook for dwellings identifies that roofspace cavities should be divided by cavity barriers so that the maximum distance between cavity barriers is not more than 10m where the cavity has surfaces which are very high risk materials.

**Conditions of Dispensation**

1. The roofspace will be provided with automatic smoke detection hard wired and interlinked to the main AFD system